

**SOLANO COUNTY WATER AGENCY
REQUEST FOR PROPOSALS (RFP)
FOR
PHASE II HET AND HEU REPLACEMENT PROGRAM**

**Responses to this Request for Proposal must be received by 4:30 pm PDT on
Wednesday, May 8, 2019**

ADDENDUM 1

The Solano County Water Agency requires the payment of Prevailing Wages pursuant to State Labor Code on all construction projects. For projects that are fully funded with the Water Agency's own funding, as in the case of the Solano HET/HEU Direct Installation Project, compliance with these statutes is left to the contractor. The contractor is required to maintain proper payroll records at their place of business and make them available in a timely manner upon request to do so by anyone. **Solano County Water Agency is not responsible to proactively certify these payroll records.**

Section 4.6 is revised to read as follows:

4.6 Urinals shall comply with ASME A112.19.2/CSA B45.1, ASME A112.19.19 OR CSA B45.5/IAMPO Z124. Wall mounted urinals shall have an average water consumption not to exceed 0.125 gallons per flush in compliance with Chapter 5, Division 5.3 of the California Green Building Standards Code (CALGreen). Other urinals shall have an average water consumption not to exceed 0.5 gallons per flush in compliance with Chapter 5, Division 5.3 of the California Green Building Standards Code (CALGreen).

Schedule revised as listed below:

The Water Agency anticipates that the process for nominating and selecting a contractor, and awarding the contract, will be according to the following tentative schedule:

Advertise and issue RFP:	April 18, 2019
Proposal due date:	4:30 PM Friday, May 3, 2019 Wednesday May 8, 2019
Oral interviews:	Monday, May 13, 2019 Thursday May 23, 2019
Selection and notification:	Friday, May 17, 2019 Tuesday May 28, 2019
Approval of Contract:	June 13, 2019
Notice to Proceed:	July 1, 2019